

## **Water Quality Results - Microbiology**

### **Carrathool**

**1 October 2023 - 31 December 2023**

Analysis Type	Characteristic	Guideline Value	Units	Min	Max	Sample Count	% meeting guideline values
Microbiology							
	E. coli	0.0000	mpn/100 mL	0	0	3	100.00
	Free Chlorine	0.2 - 5	mg/L	0.4	0.7	3	100.00
	pH	6.5 - 8.5		7.27	7.71	3	100.00
	Total Chlorine	5.0000	mg/L	0.4	0.47	2	100.00
	Total Coliforms	0.0000	mpn/100 mL	0	0	3	100.00
	Turbidity	5.0000	NTU	0.01	0.01	3	100.00