

Water Quality Results - Microbiology

Hillston

1 October - 31 December 2023

Analysis Type	Characteristic	Guideline Value	Units	Min	Max	Sample Count	% meeting guideline values
Microbiology	E. coli	0.0000	mpn/100 mL	0	0	13	100.00
	Free Chlorine	0.2 - 5	mg/L	0.6	0.89	13	100.00
	pH	6.5 - 8.5		8.09	8.3	13	100.00
	Temperature	30.0000	C	21.6	30.1	13	100.00
	Total Chlorine	5.0000	mg/L	0.62	0.89	13	100.00
	Total Coliforms	0.0000	mpn/100 mL	0	0	13	100.00
	Turbidity	5.0000	NTU	0.01	0.5	13	100.00