

Water Quality Results - Microbiology & Chemistry

Merriwagga

1 January 2023 - 31 December 2023

Analysis Type	Characteristic	Guideline Value	Units	Min	Max	Sample Count	% meeting guideline values
Microbiology							
	E. coli	0.0000	mpn/100 mL	0	0	9	100.00
	Free Chlorine	0.2 - 5	mg/L	0.46	1.09	9	100.00
	pH	6.5 - 8.5		7.15	7.8	9	100.00
	Temperature	30.0000	C	16	16	1	100.00
	Total Chlorine	5.0000	mg/L	0.5	1.19	8	100.00
	Total Coliforms	0.0000	mpn/100 mL	0	0	8	100.00
	Turbidity	5.0000	NTU	0.01	0.01	9	100.00