

# Water Quality Results - Microbiology

## Merriwagga

1 October 23 - 31 December 2023

Analysis Type	Characteristic	Guideline Value	Units	Min	Max	Sample Count	% meeting guideline values
Microbiology	E. coli	0.0000	mpn/100 mL	0	0	3	100.00
	Free Chlorine	0.2 - 5	mg/L	0.91	1.09	3	100.00
	pH	6.5 - 8.5		7.5	7.8	3	100.00
	Total Chlorine	5.0000	mg/L	0.91	1.19	2	100.00
	Total Coliforms	0.0000	mpn/100 mL	0	0	3	100.00
	Turbidity	5.0000	NTU	0.01	0.01	3	100.00