

Water Quality Results - Microbiology

Rankins Springs

1 October - 31 December 2023

Analysis Type	Characteristic	Guideline Value	Units	Min	Max	Sample Count	% meeting guideline values
Microbiology							
	E. coli	0.0000	mpn/100 mL	0	0	7	100.00
	Free Chlorine	0.2 - 5	mg/L	0.5	1.4	7	100.00
	pH	6.5 - 8.5		7.12	7.52	7	100.00
	Temperature	30.0000	C	15.9	19.1	4	100.00
	Total Chlorine	5.0000	mg/L	0.6	1.57	7	100.00
	Total Coliforms	0.0000	mpn/100 mL	0	0	7	100.00
	Turbidity	5.0000	NTU	0.01	0.35	7	100.00